DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Khampbark Chantha Heir APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10/29
PROPOSED FACILITY: 3BR MH Crawl Space PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: No
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot # 4

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear 7%	0-25"	SCR WBK	fr SS SP SEPL	DRK BRN				V5 .3
		25-39"	SCR WBK	Fr SS SP SEPL	BRN BRN Mottles				
		39-48"	SCR SBK	Fr S P SEPR					
2	Linear 5%	0-24	SCR WBK	fr SS SP SEx					V5 .3
		24-36	CR SBK	Fr SS SP SEx					
		36-48	SCR SBK	Fr SS SP SEx	37"-48" Some Chips 3" LT BRN Mottles				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	45	45
System Type(s)	Conv Conv	Conv Conv
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____