DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Khem Chanthalangsy APPLICANT: Same
ADDRESS: South Fork Rd, Lot #3 APPLICATION DATE: _____ DATE EVALUATED: 10/25/04
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 gal PROPERTY SIZE: 1.04 Ac.
LOCATION OF SITE: _____ PROPERTY RECORDED: No.
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #3

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Linear	0-10	SCL	SBK FR; SS & SP; SEP	SBK 37" (10YR)				I .3
		10-48	CL	SBK FR; SS SP; SEP					
2	Linear	0-12	SCL	SBK FR; SS SP; SEP	35 10YR				II .25
		12-32	CL	SBK FR; SS SP; SEP					
		32-48	X	ABK FI; SP; SEP					
3	Linear	0-8	SCL	G FR; SS; SEP	15" BR				II .25
		8-48	CLAY	SBK FI; SS; SEP	BR/GR				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	2's	1's
System Type(s)	Conv. Conv	Pump SP Pump
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: [signature]
OTHER(S) PRESENT: _____