IREDELL COUNTY HEALTH DEPARTMENT

37860

11860

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES P. JONES DATE 11/15/90 PERMIT NO 6K20-A-26

PHONE: Business _____ Home _____

LOCATION HSN, TL OLD WILKESBORO, TL MONTICELLO, TR MILLER FARM RD, TL SUNNYDALE AT END S. R. No. _____


SUBDIVISION NAME SUNNY DALE LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area AMPLE

Character & Porosity of Soil PS
Percolation Rate .4 GPD/FT2
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 18"
Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE BROWN

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HENDRICK DATE 11/15/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold