HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6K-20-B-5
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: TONY R. BAITY OWNER: ✓ AGENT: PHONE: 873-1718
ADDRESS: RT. 17, BOX 123 APPLICATION DATE: 12/9/93 DATE EVALUATED: 12/9/93
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE W/ BASEMENT PLBG
PROPERTY SIZE: AMPLE
LOCATION OF SITE: NC 90 W, TR. MONTICELLO, TL MILLER FARM, TL HALL DR, END ON (R)
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 4-6	0-28	C	SBK	1:1 / FR	.1942 WETNESS CONDITION: S
		28-48	SC	SBK	1:1 / FR	.1943/.1955 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 - GPD/FT²
2						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
3						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
4						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
5						.1942 WETNESS CONDITION:
						.1943/.1955 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:

AVAILABLE SPACE (.1945) D SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY / PUMP REPAIR
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: TONY & CHERYL BAITY, HOKE CRIDER
COMMENTS: 1

DRAFT