HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6K-20-B-2
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HAYDEN HAMBY OWNER: AGENT: PHONE: 871-8117
ADDRESS: 1308 MOCKSVILLE HWY APPLICATION DATE: 3/10/95 DATE EVALUATED: 3/22/95
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE ON SLAB
PROPERTY SIZE: ~125' X 419'
LOCATION OF SITE: LOT #2 SUNNYDALE II
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY		
1	L 4%	0-40	C	SBK/WABK	1:1/FI/SP	.1942 WETNES CONDITION	S
		40-50	SIC	WSBK	1:1/FR	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3 GPD/FT²
2	L 4%	0-36	C	SBK/WABK	1:1/FI/SP	.1942 WETNES CONDITION	S
		36-42	C	SBK	1:1/FR	.1943/.1956 SAPROLITE	S
		42-50	SIC	WSBK	1:1/FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3 GPD/FT²
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONVENTIONAL GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: PHYLLIS HAMBY
COMMENTS:

DRAFT

000536