IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13258

OWNER OR CONTRACTOR HERITAGE BLDG. CO. DATE 12/20/91 PERMIT NO. 90-13-A-T

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR MONTICELLO ROAD, TL MILLER FARM ROAD, TL BEECH BARK LANE, ON (L) ~0.1 MILE S. R. No. _____

SUBDIVISION NAME PINEY OAKS LOT NO. 7 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1.11 AC

Character & Porosity of Soil PS


Percolation Rate .35 GPD / FT2

Topography 4-6% LS

Depth to Water Table > 4'

Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals. BELLINGER

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345+
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by WES LYTTON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 12/20/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold