40904

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13279

OWNER OR CONTRACTOR SAMUEL G. SCOTT CONST. CO. INC DATE 10/22/91 PERMIT NO. 91-13-A-5

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR MONTICELLO DR, TL MILLER FARM RD, TL BEECH BROOK LANE, 700' ON (R) S. R. No. _____

SUBDIVISION NAME PINEY OAKS S/D LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil PS
Percolation Rate .35 GPD / FT²
Topography 6-8% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ACP 9/5/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by DAVID YOUNTS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 10/22/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold