William Elliott

203910

203910

41645

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13280

OWNER OR CONTRACTOR SAMUEL G. SCOTT CONST CO. INC DATE 2/4/92 PERMIT NO. 92-13-A-4

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR MONTICELLO DRIVE, TL MILLER FARM ROAD, TL BEECH BROOK LANE, 600' ON (R) S. R. No. _____

SUBDIVISION NAME PINEY OAKS LOT NO. 4 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area AMPLE

Character & Porosity of Soil PS
Percolation Rate .35 600 /FT²
Topography 6-8% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

new 12x24 w/ roof Existing 12x18

_____ Basement with Plumbing _____ Plumbing ✓ No Basement

ACP 11/29/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by DAVID YOUNTS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: KEEP WATER LINE MINIMUM

Location of the proposed 12'x24' deck addition does not appear to impact the existing on-site septic system or well. **NOTE:

John H Lewis REHS Date: 06/12/14
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 2/4/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold