Steel.

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR SHERRILL FAW DATE 4-14-87. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Enter Dev off Montacello Drive & circle around toward back 5th house on left before end of st. S. R. No. _____

SUBDIVISION NAME TIMBERLANE DEV. LOT NO. 14 SECTION OR BLOCK NO. _____

JOB 239

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Gen. Suitable.
Percolation Rate 4 gal/sq ft.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area Ample

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Sterling Church

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-14-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold