42330

IREDELL COUNTY HEALTH DEPARTMENT

14075 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W & W SALES, INC. DATE 2/21/92 PERMIT NO. 6K-20-A-21

PHONE: Business _____ Home _____

LOCATION NC 90 W, TR MONTICELLO DRIVE, TL MILLER FARM ROAD, ON (L) 2ND LOT PAST HAUL DRIVE S. R. No. 1544

SUBDIVISION NAME SUNNYDALE LOT NO. 3 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil PS
Percolation Rate .35 GPD/FT²
Topography 2-4% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

Lot Area AMPLE (REPAIR AREA)

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

ACP 12/16/91



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEARICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEARICK DATE 2/21/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold