DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ___ OF ___

PROPERTY I.D.#: 6K-1-B-1
DATE: 5/31/95
COUNTY: RESELL

# SOIL SITE EVALUATION FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: SHERMAN TAGGETT
ADDRESS: 47 HIGH ST.
TERRYVILLE, CT. 06786

OWNER ✓ AGENT: ___ PHONE: (203) 589-3525
APPLICATION DATE: 5/31/95 DATE EVALUATED 5/31/95
PROPOSED FACILITY: 3BR. HOUSE w/ BASEMENT
PROPERTY SIZE: 190'X 245' X 150' X 165'

LOCATION OF SITE: CORNER MONTE VISTA DR & MONTICELLO DR.
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE | .1940 LANDSCP POS./ SLOPE(%) | HORIZON DEPTH (IN.) | .1941 (1)(1) TEXTURE | .1941 (1)(2) STRUCTURE | .1941 (1)(3) MINERALOGY | MATRIX COLOR | MOTTLE COLOR | OTHER PROFILE FACTORS |
|---|---|---|---|---|---|---|---|---|
| 1 | L | 0-48 | C | A/SBK | i:l / FI | | | .1942 Wetness Cond. S |
| | 2% | | | | | | | .1943 Depth/.1956 Sapr. S |
| | | | | | | | | .1944 Restrictive Hori. S |
| | | | | | | | | .1948 Profile Class. PS |
| | | | | | | | | Profile LTAR 0.3 |
| | | | | | | | | .1942 Wetness Cond. |
| | | | | | | | | .1943 Depth/.1956 Sapr. |
| | | | | | | | | .1944 Restrictive Hori. |
| | | | | | | | | .1948 Profile Class. |
| | | | | | | | | Profile LTAR |
| | | | | | | | | .1942 Wetness Cond. |
| | | | | | | | | .1943 Depth/.1956 Sapr. |
| | | | | | | | | .1944 Restrictive Hori. |
| | | | | | | | | .1948 Profile Class. |
| | | | | | | | | Profile LTAR |
| | | | | | | | | .1942 Wetness Cond. |
| | | | | | | | | .1943 Depth/.1956 Sapr. |
| | | | | | | | | .1944 Restrictive Hori. |
| | | | | | | | | .1948 Profile Class. |
| | | | | | | | | Profile LTAR |

SUITABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.30 GPD/FT²

EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: SHERMAN TAGGETT

COMMENTS:

002959