IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

9368

OWNER OR CONTRACTOR Earl Anderson DATE 5/8/89 PERMIT NO. 00

PHONE: Business _____ Home _____

LOCATION Mill & Mooresville Hudson Left on Rt 64 200 yards S. R. No. _____

SUBDIVISION NAME Hudson LOT NO. 39 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 Ac

Character & Porosity of Soil prgr sandy clay
Percolation Rate 14
Topography 2 to 6 %
Depth to Water Table 10 ft
Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by James Huddler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY [illegible] Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 5/8/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Location of the proposed SCREENED PORCH addition does not appear to impact the existing on-site septic system.**NOTE: KEEP MIN 5' FROM SYSTEM & SHALE BEDROCK REHS

Date: 3-12-2013

ICHD-Environmental Health Division