## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William C. Caldwell DATE 12/13/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Monticello Drive to Millin Rd # 1544. Go to Hillside Baptist Church. House back off Road behind Church S. P. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Prev Suitable | |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2 – 6% Slope | |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | Low | |
| | | | Rock or other impervious formations | | |

Lot Area Acreage




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/13/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold