IREDELL COUNTY HEALTH DEPARTMENT

CITY IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

PART OF 00002

OWNER OR CONTRACTOR C. DOUGLAS MADISON, JR. DATE 7/15/92 PERMIT NO. 6K-A-85

PHONE: Business 873-0521 Home

LOCATION NC 90 W, TR MONTICELLO DRIVE, TR BRADLEY FARM ROAD, TR CARINGTON LANE, 2ND LOT ON (L) S.R. No.

SUBDIVISION NAME CARINGTON LOT NO. 2 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 100' X 150'

Soil Characteristics PS

Application Rate 0.40 GPD / FT²

Topography 2-4% LINEAR SLOPE >4

Depth to Water Table

Rock or other impervious formations NONE

☐ Basement with Plumbing ☐ Basement without Plumbing ☑ No Basement ☐ Crawl Space

ACP 5/27/92 Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑



Plot of System (Not to Scale)

Installed by A-1 BACKHOE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 7/15/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold