HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6K-A-8A
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: EARL ANDERSON OWNER: ✓ AGENT: PHONE: 872-8175
ADDRESS: 453 HUMMINGBIRD LANE APPLICATION DATE: 1/12/94 DATE EVALUATED: 1/21/94
STVL, NC 28677 PROPOSED FACILITY: 4 BR HOUSE
PROPERTY SIZE: 18 ACRES
LOCATION OF SITE: NC 90W, TR MONTICELLO, TL MEADOWLARK, TR BLUEJAY WAY, DRIVE AT END.
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 4%	0-6	SC	SBK	1:1 / FR	.1942 WETNESS CONDITION	S -
		6-36	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S -
		36+	C/SAP.	SBK	1:1 / FI	.1944 RESTRICTIVE HORIZON	S -
						.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.30 GPD/FT²
2	N 4%	0-4	SC	SBK	1:1 / FR	.1942 WETNESS CONDITION	S -
		4-24	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S (EVAL W/ P-)
		24-48	C/SAP	SBK/GR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S -
						.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.30 GPD/FT²
3	N 2%	0-6	SC	SBK	1:1 / FR	.1942 WETNESS CONDITION	S -
		6-26	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S (EVAL W/ PIT)
		26-45	C/SAP	SBK/GR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S -
		48"	ROCK			.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.30 GPD/FT²
4	N 2%	0-6	SC	SBK	1:1 / FR	.1942 WETNESS CONDITION	S -
		6-24	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	U - (EVAL W/ PIT)
		24-38	SAP			.1944 RESTRICTIVE HORIZON	U -
		38+	ROCK			.1948 PROFILE CLASSIFICATION	U -
						PROFILE LTAR	-
5	N 3%	0-4	SC	SBK	1:1 / FR	.1942 WETNESS CONDITION	S -
		4-28	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S (EVAL W/ PIT)
		28-48	C/SAP	SBK/GR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S -
						.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.30 GPD/FT²

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: EARL ANDERSON, JACK MOORE, MIKE DENNIS
COMMENTS: INITAL P.D. FOR LOT #15 // SPACE AVAILABLE INADEQUATE // ENTIRE TRACT RECORDED FOR NEW P.D. #17721

DRAFT

0028688