IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR
OWNER OR CONTRACTOR MIKE MUNAY DATE 3/5/92 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL OLD WILKSBORO ROAD, TL MONTICELLO DR, 6th HOUSE ON (R) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table EXISTING
Rock or other impervious formations _____

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank _____ Gals.
Nitrification Field:
No. of Lines EXISTING
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)

Installed by JAMES HUBLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: ① NEW SANITARY TEE INSTALLED IN TANK, NEW D. BOX INSTALLED. ② SYSTEM FED SERIALLY AS INDICATED ON DIAGRAM. ③ FUTURE REPAIR AREA IS BETWEEN LINES #1 & 2 LOCATED IN FRONT YARD.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 3/5/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold