DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 472597110 9
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Fawn Combs
ADDRESS: 124 Feimster St
PROPOSED FACILITY: SFD
PROPOSED DESIGN FLOW (.1949): 2 bdrm
LOCATION OF SITE: 119 Classic Ln
WATER SUPPLY: • Private • (Public) • Well • Spring • Other N/A
EVALUATION METHOD: • (Auger Boring) • Pit • Cut
APPLICATION DATE 8-8-14
DATE EVALUATED: 8-28-14
PROPERTY SIZE: 0.259 acres
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: • (Sewage) • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3% L	0-48	BCCL sap Incl WSSL	Fr mod SE	48"	48"	48"	48"	PS 0.3
2	5% L	0-48	BCCL sap Incl WSSL	Fr mod SE	48"	48"	48"	48"	PS 0.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		PS
stem Type(s)		II
e LTAR		0.3

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): S5
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: ~~Justin~~ Heath Snow

IMENTS: