IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Statesville - Mooresville Home Bldrs. Assn. DATE 3/31/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION House on Corner of old Wilkesboro Rd and Northmont Drive S. R. No. _____


SUBDIVISION NAME Northmont LOT NO. 44 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Prov Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Wilkesboro Rd
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 20,000 sq ft



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts to be Put underground and directed across and away from septic tank lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3/31/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold