IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR NORMAN W. WALTERS DATE 11-12-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Merriment Acres - Turn into dev. (upper drive), T.L. on 1st street - 2nd house on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2.5

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	sandy clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	5 gal/sq.ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	none observed.

Lot Area 17,780 sq.ft.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-12-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold