01058

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George S. Klinger DATE 8-7-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N TL on Old 115 To Northmont

_____ S. R. No. _____

SUBDIVISION NAME Northmont LOT NO. 70 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 19,781

Character & Porosity of Soil [redacted] Clay


Percolation Rate 135 c.

Topography Slight

Depth to Water Table 10'

Rock or other impervious formations Hard Rock 36" + Soft granular saprolite 18 to 36"

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Eddie Yountz + Son

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 8-7-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold