IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. A Daniels DATE 2/20/78 PERMIT NO.

PHONE: Business Home

LOCATION Northmont Sub Division N of old Wilkesboro Rd

SUBDIVISION NAME Northmont LOT NO. 69 SECTION OR BLOCK NO. S. R. No.


House (+) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (+)	No ( )
Auto. Dishwasher	Yes (+)	No ( )
Auto. Wash. Machine	Yes (+)	No ( )
Site Suitable	Yes (+)	No ( )

Lot Area 20 000 sq ft+

Character & Porosity of Soil Pan Suitable
Percolation Rate
Topography Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (+)

Installed by B. A. Daniels

IMPROVEMENTS PERMIT BY

COMMENTS: 1/2 Well tile to be put over openings in tank for Maintenance Purposes.

CERTIFICATE OF COMPLETION BY E. H. Stevenson DATE 2/20/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold