IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Stikeleather DATE 4/30/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 90 to Loray - T.R. on Rd # 1548. T.R. on Scotts Rd #1551 1st House on Rt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope Low
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	None

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 210
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlan Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lot to be graded so water will not stand over Drainfield. Layout Changed due to well being put where original layout was

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 4/30/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold