IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Junior Lewis DATE 10/26/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 N. Tlt. on Scotts Rd. Double Wide Home on L. Just before Rd #1548

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil _____


Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Existing System



Plot of System

Size of Tank _____ Gals.

Nitrification Field:

No. of Lines _____

Sq. Ft. _____ Linear Ft. _____

Depth of Stone in Lines _____

Water Supply: Individual ( )

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: This existing sewage system showed no signs of surfacing at time of inspection. Fresh dirt should be filled in over low places in line. Grade so water will not stand over lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold