Sheet ___ of ___

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 47263164910000
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: A.J. BUILDING CO. APPLICANT: JEFF WICKER
ADDRESS: 147 HUNTER RIDGE RD STATESVILLE NC APPLICATION DATE: 1-7-99 DATE EVALUATED: 1-26-99
PROPOSED FACILITY: 3BR/HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.699 ACRE
LOCATION OF SITE: DEERCROFT IV # 168 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 8%	0-48	SBK / C	SS/P.FI/NEXP					PS 0.25
2	L 10%	0-48	SBK / C	SS/P.FI/NEXP					PS 0.25
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HENDRICK
OTHER(S) PRESENT: JEFF WICKER