HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 18769
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: FRANK WHITING OWNER: ✓ AGENT: ✓ PHONE: 876-3039
ADDRESS: 239 SHUMAKER DR APPLICATION DATE: 7/21/99 DATE EVALUATED: 7/21/99
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: ~330' x ~330'
LOCATION OF SITE: DEERCROFT II 151
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 4%	0-8	CL	WABK	1:1 / FI	.1942 WETNES CONDITION	S
		8-40+	C	WABK	MIX 1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.20
2	N 5%	0-9	CL	WABK	1:1 / FI	.1942 WETNES CONDITION	S
		9-38+	C	WABK	MIX 1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.20
3	N 4%	0-6	CL	WABK	1:1 / FI	.1942 WETNESS CONDITION	S
		6-40+	C	WABK	1:1 / FI	.1943/.1956 SAPROLITE	S
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.20
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.20 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY SHALLOW RACEWAY
EVALUATED BY: ___ OTHER(S) PRESENT: FRANK WHITING & WIFE
COMMENTS: ___

DRAFT