SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#:
DATE: 10-28-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

838-2779

APPLICANT: LARRY MUNDAY BUYERS
ADDRESS: 673 SHILOH RD
STVL, NC 28677

OWNER/AGENT: PHONE: 872-6019
APPLICATION DATE: 10/12/95 DATE EVALUATED 10/25/95
PROPOSED FACILITY: 3 BR HOUSE W/C.S.
PROPERTY SIZE: 110' X 250' ±

LOCATION OF SITE: DEERCROFT #136
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. S
	10%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.25 GPD
2	F	0-40	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. PS
	6%	40+	MOTTLES			2.	2.5YR 5/2	.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.25 GPD
3	SLIGHT H	0-40	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. PS
	6%	40+	MOTTLES				2.5YR 7/2	.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.25 GPD
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.25 GPD/FT²

EVALUATED BY: S. HENDRICK OTHER(S) PRESENT: LARRY MUNDAY

COMMENTS: SUBSURFACE INTERCEPT DRAIN REQUIRED

0016300