HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-127
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: KENNETH A. WATT OWNER: ✓ AGENT: PHONE: 876-0097
ADDRESS: 129 BECKHAM ROAD APPLICATION DATE: 5/23/95 DATE EVALUATED: 5/23/95
STATESVILLE, NC PROPOSED FACILITY: 3 BR HOUSE
28677 PROPERTY SIZE: 110' x 250'
LOCATION OF SITE: # 127 DEERCROFT III
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 10%	0-48	C	WSBK	1:1/FI/SP/SS	.1942 WETNESS CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25
2	N 8%	0-48	C	WSBK	1:1/FI/SP/SS	.1942 WETNESS CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.25
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.25
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY / CHAMBER REPAIR
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: KENNETH WATT, EDDIE (?)
COMMENTS: BOIL DEPTH IS GOOD, HOWEVER, LINES SHOULD BE KEPT SHALLOW DUE TO PLASTICITY & STICKINESS OF SOIL.

DRAFT

00209