HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-119
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: G & G BUILDERS OWNER: AGENT: ✓ PHONE: 871-7295
ADDRESS: 184 SERENITY DR APPLICATION DATE: 9/20/99 DATE EVALUATED: 9/20/99
MOCKSVILLE, NC 27028 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110' x 285'
LOCATION OF SITE: # 119 DEERCROFT
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	SLIGHT N	0-8	C	~~SBK~~	1:1 / FR	.1942 WETNESS CONDITION S
		8-38	C	ABK	MIXED 1:1 / FI	.1943/.1956 SAPROLITE S
		38-48	C	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2	SLIGHT N	0-8	C	SBK	1:1 / FR	.1942 WETNESS CONDITION S
		8-39	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
		39-48	C	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MIKE GAITHER
COMMENTS:

DRAFT