DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Wayne Homes APPLICANT: Same
ADDRESS: 139 Seed Rock Dr. Mid-county APPLICATION DATE: 2-2001 DATE EVALUATED: 2/5/00
PROPOSED FACILITY: 3BR Dom/Com PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .6
LOCATION OF SITE: Hwy 115 N, (S. of Creek) Mike Farm Rd, R Apple PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other In Front of Road
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #177

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Linear 6%	0-24	C mod	Fi SP SE					PS .25
		24-41	CL/mod mod	Fi SP					
2	Linear 6%	0-24	C mod blk	Fi SP SE					PS .25
		32-43	CL/mod blk	Fi SP SE					
		43-?	Rock						
3	Linear 6% Lo P.V.	0-23	CL mod blk	SP					PS .30
		23-33	CL SBK mod blk	SP					
		33-39	CL mod blk	SS SP					
		39-49	CL/Sap	SS SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Reduction Conv.	Conv. 50% Red.
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: William O. Johnson
OTHER(S) PRESENT: _____