HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 1701
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JEFFREY TODD ELLIS OWNER: AGENT ✓ PHONE: 878-6633
ADDRESS: RT. 15, 1 Box 19 APPLICATION DATE: 9/28/93 DATE EVALUATED: 9/28/93
STL, NC 28677 PROPOSED FACILITY: 3 BR House
PROPERTY SIZE: ~110 x 288
LOCATION OF SITE: LOT 64 DEERCROFT S/D
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 2-4	0-48	C	SBK	1:1 / FR	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT2
2	N 2-4	0-48	C	SBK	1:1 / FR	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT2
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HENDRICK OTHER(S) PRESENT: JEFFREY TODD ELLIS, WAYNE POPE
COMMENTS:

DRAFT

0068