HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED: 9A-9-A-68
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG Co. OWNER: ✓ AGENT: PHONE: 528-6699
ADDRESS: Rt-10, Box 177-A APPLICATION DATE: 2/22/99 DATE EVALUATED: 2/22/99
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110 x 239
LOCATION OF SITE: DEERCROFT #68
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-8	CL	GR	1:1 / FR	.1942 WETNESS CONDITION: S
		8-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33 GPD/FT²
2						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
3						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
4						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
5						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK DYSON
COMMENTS:

DRAFT

000660