HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: 9A-9-A-77
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG. CO. OWNER: ✓ AGENT: PHONE: 528-6649
ADDRESS: RT. 10, BOX 177-A APPLICATION DATE: 2/22/99 DATE EVALUATED: 2/22/99
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110 x 239
LOCATION OF SITE: DEERCROFT #77
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1941 LANDSCP POS SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	SLGHT H 4%	0-8	CL	GR	1:1 / FR	.1942 WETNESS CONDITION: S
		8-48	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 GPD/FT²
2						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
3						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
4						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
5						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1948): NONE SYSTEM TYPE: 3BR HOUSE
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK DYSON
COMMENTS:

DRAFT