DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED 9A-9A-76.
COUNTY IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG. Co. OWNER: ✓ AGENT: PHONE: 528-6699
ADDRESS: RT. 10, BOX 177-A APPLICATION DATE: 2/22/99 DATE EVALUATED: 2/22/99
STVL, NC 28677 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 110 x 239
LOCATION OF SITE: DEERCROFT # 76
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	
1	N 4%	0--4	C	GC	1:1/FR	.1942 WETNESS CONDITION S
		4-48	C	~~SA~~BK	1:1/FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1945 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK DYSON
COMMENTS:

DRAFT