HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-61
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: TIM ALEXANDER OWNER: ✓ AGENT: PHONE: 876-1653
ADDRESS: Rt. 2, Box 12B APPLICATION DATE: 9/21/93 DATE EVALUATED: 9/21/93
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110' x 275'
LOCATION OF SITE: DEERCROFT #61
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ✓

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N 0-2	0-48	C	SBK	1:1 /FR	.1942 WETNES CONDITION S .1943/.1956 SAPROLITE S .1944 RESTRICTIVE HORIZON S .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35
2	L 2-4	0-48	C	SBK	1:1/FR	.1942 WETNES CONDITION S .1943/.1956 SAPROLITE S .1944 RESTRICTIVE HORIZON S .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35
3						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR
4						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR
5						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: TIM ALEXANDER
COMMENTS:

DRAFT