HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-72
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DAN MAHAFFEY OWNER: ✓ AGENT: PHONE: 876-1797
ADDRESS: RT. 17 Box 193 APPLICATION DATE: 9/18/94 DATE EVALUATED: 9/18/94
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110 X 239
LOCATION OF SITE: #72 DEARCOFT
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 3%	0-14	CL	GR	1:1 / FR	.1942 WETNES CONDITION 5
		14-98	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2	L 3%	0-12	SCL	GR	1:1 / FR	.1942 WETNES CONDITION 5
		12-48	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DAN MAHAFFEY
COMMENTS:

DRAFT