HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-112.
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RONALD P. CAMPBELL OWNER: ✓ AGENT: PHONE: 492-7810
ADDRESS: Rt. 1, Box 327 APPLICATION DATE: 2/4/99 DATE EVALUATED: 2/4/99
STVL, NC 28677 PROPOSED FACILITY: 3 BR House
PROPERTY SIZE: 110 x 200
LOCATION OF SITE: Lot # 112 DEERCROFT
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other: EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY	
1	L 3%	0-20	C	SBK	1:1 / FI	.1942 WETNES CONDITION: S
		20-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1945 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33
2	L 3%	0-18	C	SBK	1:1 FI	.1942 WETNES CONDITION: S
		18-48	C	ABK	1:1 FI	.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1945 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33
3	L 3%	0-18	C	SBK	1:1 FI	.1942 WETNESS CONDITION: S
		18-48	C	ABK	1:1 FI	.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1945 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33
FRONT 4	L 3%	0-8	L	SBK	1:1 / FR	.1942 WETNESS CONDITION: S
		8-20	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE: S
		20-48	C	ABK	1:1 / FI	.1944 RESTRICTIVE HORIZON: S
						1945 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.33
5						.1942 WETNESS CONDITION:
						.1943/.1956 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1945 PROFILE CLASSIFICATION:
						PROFILE LTAR:

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1945): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MIKE GAITHER
COMMENTS:

DRAFT