HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 94-9-A-108
PROPERTY RECORDED:
COUNTY: REESELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Fr. J. Jimmy Bustle OWNER: AGENT: ✓ PHONE: 876-2203
ADDRESS: Rt. 11, Box 119 APPLICATION DATE: 10/21/93 DATE EVALUATED: 10/21/93
Stk, NC 28677 PROPOSED FACILITY: 3BR (H)
PROPERTY SIZE: 110' x 200'
LOCATION OF SITE: NC 115 N, TL SCOTTS CREEK, TL MILLER FARM, TR DOE TRAIL, TR ELK DR ON (R)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___
LOT # 108 DEERCROFT SECT. II

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 0-2	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION S .1943/.1956 SAPROLITE S .1944 RESTRICTIVE HORIZON S .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35 GPD/FT²
2	L 0-2	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION S .1943/.1956 SAPROLITE S .1944 RESTRICTIVE HORIZON S .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION - .1943/.1956 SAPROLITE - .1944 RESTRICTIVE HORIZON - .1948 PROFILE CLASSIFICATION - PROFILE LTAR -
4						.1942 WETNESS CONDITION - .1943/.1956 SAPROLITE - .1944 RESTRICTIVE HORIZON - .1948 PROFILE CLASSIFICATION - PROFILE LTAR -
5						.1942 WETNESS CONDITION - .1943/.1956 SAPROLITE - .1944 RESTRICTIVE HORIZON - .1948 PROFILE CLASSIFICATION - PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) N/A SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JIMMY BUSTLE, DAN MAHAFFEY, PETE SCOTT
COMMENTS:

DRAFT