SOIL SITE EVALUATION

FOR

ON-SITE WASTEWATER SYSTEM

APPLICANT Wtw Sales OWNER AGENT PHONE:

ADDRESS: APPLICATION DATE: DATE EVALUATED:

PROPOSED FACILITY:

PROPERTY SIZE:

LOCATION OF SITE:

WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit

PROFILE #	.1946 LANDSCAPE POSITION	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1943 WETNESS COND.	.1944 RESTRICT HORIZONS	.1942 CLASS OF HORIZ	1957/ 1956 SAPRIST CLASS.	HO L
1	Linear 3%	0 to 30	C SbK	SEAP ss sp	Ps	Ps	Ps	N/A	.35
		30 to 48	Scl WSbK	NEAP					
2	Linear 4%	0 to 48	C SbK	SEAP ss sp	Ps	Ps	Ps	N/A	.3
3									
4									
5									

AVAILABLE SPACE (.1942): Yes SOIL CLASSIFICATION (.1943): SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: T.C. Moore OTHER(S) PRESENT:

COMMENTS:

00384