HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9D- A-18 (86)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

LOT 86 BEECROFT

APPLICANT: THOMAS BEATY OWNER: AGENT / PHONE: 878-2244 / 871-6947
ADDRESS: RT 2, BOX 91-A APPLICATION DATE: 8/25/93 DATE EVALUATED: 8/25/93
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110 x 200'
LOCATION OF SITE: NC115N, TL [redacted] CREEK RD, TL MILLER FARM RD, TR DOE TRAIL, TR ELK AP, TR CARIBOU RD, 2ND LOT ON (R)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 1%	0-20	C	SBK	1:1 / FR	.1942 WETNES CONDITION S
		20-48	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE N/A
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2	L 1%	0-24	C	SBK	1:1 / FR	.1942 WETNES CONDITION S
		24-48	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE N/A
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY (REPAIR - SAME)
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: BRUCE PORTER
COMMENTS:

DRAFT