DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9A-9-A-103
DATE: 9-7-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: HELLMAN CONSTRUCTION
ADDRESS: 188 KNOX FARM RD STATESVILLE, NC 28677
OWNER ✓ AGENT: PHONE: 878-6484
APPLICATION DATE: 8-30-95 DATE EVALUATED 9-7-95
PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 110' X 200'±
LOCATION OF SITE: # 103 DEERCHASE II
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	C	SBK	(1) /57			.1942 Wetness Cond. S
	22%							.1943 Depth/.1956 Sapr. 2
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3 GPD
2								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS
SYSTEM TYPE CONV. GRAVITY LONG-TERMACCEPTANCE RATE(S) 0.3
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: JACK BARBERS
COMMENTS:

0006955