IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR
OWNER OR CONTRACTOR JOHNNIE CLANTON DATE 5/28/91 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION NC 115 N, TL SCOTTS CREEK RD, ~ 1.5 MI ON (R) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.4 GPD/FT2
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4% LS
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	> 4'
			Rock or other impervious formations	NONE

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 270 Linear Ft. 90
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by FORREST SHUFFORD

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 5/28/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold