DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: SR. Bldg Co. APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9/20/00
PROPOSED FACILITY: BBQ House/Lounge PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .75 Ac.
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

1000 480 gpd → 360 - 25%
40 - 5%
#17

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	CC 7% Linear	0-20	sl	FrA SP SEXP	18"				PS .25
		20-48	c ASK	fi SP SEXP					
2	6% Linear	0-4	sl	Fr NS NP NEXP	18"				PS .25
		4-26	c/sc ASK	fi SP SEXP					
		26-48	c ASK	fi SP SEXP					
3	3% Linear Rear	0-16	SCL WEAK	Fr SS NP SEXP					PS .25
		16-48	c ASK	fi SP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 25% Red	Gravity 50% Red
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____