DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DAVID PERRY
ADDRESS: 332 YORK SPANN RD HAMPTONVILLE, NC 27020
PROPOSED FACILITY: 3BR H
PROPOSED DESIGN FLOW (.1949): 360
LOCATION OF SITE: FAWNWOOD #3

APPLICATION DATE 12-21-04
DATE EVALUATED: 3-1-05
PROPERTY SIZE: 0.527
PROPERTY RECORDED:

WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 6%	0-32	SBK C	FR SEXP					PS 0.3
		32-48	SBK SC	FR SS/SP SEXP					
2	L 5%	0-30	SBK C	FR SEXP					PS 0.3
		30-48	SBK MICACEOUS SC	FR SS/SP SEXP					
3	SS 2%	0-28	SBK C	FR SEXP					PS 0.3
		28-48	SBK SC	FR SS/SP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	~~PS~~ S	PS
System Type(s)	II	IV
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: DAVID PERRY

COMMENTS: