HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-1-19
PROPERTY RECORDED:
COUNTY: REDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: AUSTIN & AUSTIN BLDRS OWNER: ✓ AGENT: PHONE: 876-0105
ADDRESS: RT. 9 Box 41R-B APPLICATION DATE: 3/1/94 DATE EVALUATED: 3/1/94
STVL, NC 28677 PROPOSED FACILITY: 3BR House
PROPERTY SIZE: 110 X 200
LOCATION OF SITE: DEERCROFT # 19
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 6-8%	0-12	C	SBK	1:1 / FR	.1942 WETNES CONDITION S
		12-38	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
		38-48	SC	SBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT2
2						.1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HERRICK OTHER(S) PRESENT: GARY AUSTIN
COMMENTS:

DRAFT