HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-52
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: SELF HOMES INC OWNER: ✓ AGENT: PHONE: 873-9612
ADDRESS: P.O. BOX 1283 APPLICATION DATE: 2/24/94 DATE EVALUATED: 2/24/94
STVL, NC 28687 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110 X 300
LOCATION OF SITE: DEERCROFT #52
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N	0-32	C	SBK	1:1/FI	.1942 WETNES CONDITION S
		32-48	SC	SBK	1:1/FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT2
2						.1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: BILLY SELF, BENNY WILSON
COMMENTS:

DRAFT