HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 9A-9-A-99
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: A.J. BLDG. CO., OWNER: ✓ AGENT: PHONE: 871-0940
ADDRESS: 1068 MOCKSVILLE RD APPLICATION DATE: 2/3/99 DATE EVALUATED: 2/3/99
STVL NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 110' x 252'
LOCATION OF SITE: LOT # 99 DEERCROFT (WATTS LANE)
WATER SUPPLY: On-Site Well ___ Comm Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	1941 LANDSCP POS. SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINEROLOGY	
1	L 2%	0-16	C	SBK	I:1 / FR	1942 WETNESS CONDITION 5
		16-48	C	WABK	I:1 / FI	1943/1956 SAPROLITE 5
						1944 RESTRICTIVE HORIZON 5
						1945 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2						1942 WETNESS CONDITION
						1943/1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						1945 PROFILE CLASSIFICATION
						PROFILE LTAR
3						1942 WETNESS CONDITION
						1943/1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						1945 PROFILE CLASSIFICATION
						PROFILE LTAR
4						1942 WETNESS CONDITION
						1943/1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						1945 PROFILE CLASSIFICATION
						PROFILE LTAR
5						1942 WETNESS CONDITION
						1943/1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						1945 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. EQUITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JEFFREY WHICKER
COMMENTS:

DRAFT