DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 9A-9-A-89
DATE: 10-19-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: CHRISTEN HAYZLIP
ADDRESS: TAYLORSVILLE, NC 28681
OWNER ✓ AGENT: PHONE:
APPLICATION DATE: 10-9-95 DATE EVALUATED 10-19-95
PROPOSED FACILITY: 3BR HOUSE W/BASEMENT
PROPERTY SIZE: 117' X 200'
LOCATION OF SITE: DEERCROFT II, LOT # 89
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	H 4%	0-48	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. S .1943 Depth/.1956 Sapr. -S .1944 Restrictive Hori. -S .1948 Profile Class. PS Profile LTAR 0.3
2	H 6%	0-48	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. -S .1943 Depth/.1956 Sapr. -S .1944 Restrictive Hori. -S .1948 Profile Class. -PS Profile LTAR -0.3
3	H 4%	0-6 6-48	FILL MATERIAL C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. -S .1943 Depth/.1956 Sapr. -S .1944 Restrictive Hori. -S .1948 Profile Class. PS Profile LTAR 0.3
4								.1942 Wetness Cond. - .1943 Depth/.1956 Sapr. - .1944 Restrictive Hori. - .1948 Profile Class. - Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GAD/AR

EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: LARRY HAYZLIP

COMMENTS: SUBSURFACE INTERCEPT DRAIN MAY BE REQUIRED