ALTH. & NATURAL RESOURCES
ISION OF ENVIRONMENTAL HEALTH
SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED: 9A-9-A-93
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: SAMUEL G. SCOTT OWNER: AGENT: ✓ PHONE: 873-1391
DDRESS: 2310 S. CHIPLEY FORD APPLICATION DATE: 10/11/99 DATE EVALUATED: 10/12/99
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: ~110' x 220'
OCATION OF SITE: DEERCROFT #93
ATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 4%	0-10	SC	GR	1:1/FR/SP	.1942 WETNES CONDITION S
		10-48	C	WABK	1:1/FI/SP-P	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33
2	H 3%	0-8	SC	GR	1:1/FR/SP	.1942 WETNES CONDITION S
		8-48	C	WABK	1:1/FI/P	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33
3	L 2%	0-6	FILL DIRT $			.1942 WETNESS CONDITION S
		6-10	SC	GR	1:1/FR	.1943/.1956 SAPROLITE S
		10-48	C	WABK	1:1/FI/P	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GRD/PT²
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: SAMUEL G SCOTT
COMMENTS: SURFACE DRAINAGE DITCH

DRAFT

0001695