HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 17169
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: G & G BUILDERS OWNER: AGENT: ✓ PHONE: (704) 492-7810
ADDRESS: RT. 1, BOX 322 APPLICATION DATE: 8/8/93 DATE EVALUATED: 10/8/93
MOCKSVILLE, NC PROPOSED FACILITY: 3BR, HOUSE
27028 PROPERTY SIZE: ~110' X 210'
LOCATION OF SITE: LOT # 12 DEERCROFT S/D
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 6-10	0-6	SC	GR	1:1 / FR	.1942 WETNES CONDITION S
		6-32	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
		32-48	SC	ABK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GPD/FT²
2						.1942 WETNES CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT:
COMMENTS:

DRAFT

000747