45271

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15417

OWNER OR CONTRACTOR SAMUEL G. SCOTT DATE 4/23/93 PERMIT NO. 9A-9-A-8

PHONE: Business _____ Home _____

LOCATION NC90W, TR MONTICELLO DRIVE, TL MILLER FARM ROAD, TL DOE TRAIL, LOT #8 ON (R) S.R. No. _____

SUBDIVISION NAME DEERCROFT LOT NO. 8 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 110' x 200'

Soil Characteristics PS

Application Rate 0.35 GPD / FT²

Topography 6-8% NOSE SLOPE

Depth to Water Table 54"

Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space

ACP 2/13/93

Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 4

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑



Plot of System (Not to Scale)

Installed by DAVID YOUNTZ

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE)

MILLER FARM ROAD

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL, COUNTY RD

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 4/23/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold